



Internet: www.awqc.com.au

Email: producttesting@awqc.com.au

FINAL REPORT

Report ID : 304414

Report Information

Submitting Organisation : 00120908 : Lanotec Australia Pty Ltd
Account : 141647 : Lanotec Australia Pty Ltd
AWQC Reference : 141647-2020-CSR-1 : Prod Test: Lanolin Release Agent (Cementitious Cubes)
Project Reference : PT-4437
Product Designation : Release Agent
Composition of Product : Lanolin base with solvent, water and emulsifiers
Product Manufacturer : Lanotec Australia Pty Ltd, Archerfield, QLD.
Use of Product : Concrete mould release agent.
Sample Selection: As provided by the submitting organisation
Testing Requested : **AS/NZS 4020 TESTING OF PRODUCTS FOR USE IN CONTACT WITH DRINKING WATER**
Product Type : Composite
Samples : Samples were prepared and controlled as described in Appendix A of AS/NZS 4020:2018
Extracts : Extracts were prepared as described in Appendix/Clause C, D, E, F, G, H, 6.8.
Project Completion Date : 05-Mar-2021
Project Comment : The results presented herein demonstrate compliance to AS/NZS 4020 for Lanolin Release Agent (Cementitious Cubes) when tested exposed at surface area to volume ratios up to 15,000mm²/L at 20°C ± 2°C.

PLEASE NOTE THAT THIS REPORT SHALL NOT BE REPRODUCED EXCEPT IN FULL

THE RESULTS STATED IN THIS REPORT RELATE TO THE SAMPLE OF THE PRODUCT SUBMITTED FOR TESTING. ANY CHANGES IN THE MATERIAL FORMULATION, PROCESS OF MANUFACTURE, THE METHOD OF APPLICATION, OR THE SURFACE AREA-TO-VOLUME RATIO IN THE END USE, COULD AFFECT THE SUITABILITY OF THE PRODUCT FOR USE IN CONTACT WITH DRINKING WATER

Michael Glasson
APPROVED SIGNATORY



Corporate Accreditation No.1115
Chemical and Biological Testing
Accredited for compliance with ISO/IEC 17025

